

November 4, 2011

Mr. Bert Luistro
Program Manager
UCSF - Main Campus
Office of Environmental Health & Safety
50 Medical Center Way
San Francisco, CA 94143

SIC/ID: 8221/00934

**SUBJECT: Pollutant analytical results: UCSF Parnassus Site B
(Back in Compliance)**

Dear Mr. Bert Luistro :

The Wastewater Enterprise/Collection System Division recently collected grab and composite samples from one waste stream, which discharge from UCSF Parnassus, Site B into the City and County of San Francisco's sewerage system. All of the sampling and analyses were performed in accordance with procedures established by the Environmental Protection Agency (EPA) pursuant to Section 304 (g) of the Clean Water Act, and contained in 40 CFR Part 136, and amendments thereto. Summaries of the analyses are enclosed.

The analytical results show that during the monitored period, your facility's process wastewater discharges are now back in compliance with the City and County of San Francisco's discharge limits for **zinc** and other heavy metals. Those limits are contained in Section 123(a) of Chapter X (Public Works Code) of Part II of the San Francisco Municipal Code, Article 4.1 ("Article 4.1"), and in DPW Order No. 158170.

Please note that compliance during the monitored period does not alter your continuing duty to comply with all of the limitations and prohibitions contained in your facility's permit, and/or in Section 123 of Article 4.1.

If you have any questions about the information provided, please contact Dr. John Gregson at 415-695-7358.

Sincerely,



Bruce Seale, Acting Manager
Pretreatment Program
Wastewater Enterprise / Collection System Division

Enclosure

CITY AND COUNTY OF SAN FRANCISCO
Wastewater Enterprise/Collection System Division
 TOXIC POLLUTANT COMPLIANCE MONITORING REPORT

DATE: 11/04/2011

SOURCE **UCSF - Main Campus, SITE B (Emergency exit driveway - Site B)**

REQUEST **23987**

DAY	Sample Date	TOXIC POLLUTANT ANALYSIS TABLE (mg/L)*										
		[As]	[Cd]	[Cr]	[Cu]	[Pb]	[Hg]	[Ni]	[Ag]	[Zn]	[CN(T)]	Phenols
1	10/07/11	ND	0.003	0.040	0.765	0.203	0.0007	0.072	0.013	1.234		
2	10/12/11	ND	ND	ND	0.040	ND	ND	ND	ND	0.112		
3	10/13/11	ND	ND	ND	0.042	ND	ND	0.007	ND	0.163		
4	10/14/11	ND	ND	ND	0.054	ND	ND	0.006	ND	0.191		
5	10/18/11	ND	ND	ND	0.052	ND	ND	0.006	ND	0.135		
AVERAGE VALUES (mg/L)		ND	ND	0.008	0.191	0.041	ND	0.018	ND	0.367		

COMPLIANCE STATUS

CCSF LOCAL LIMITS	4.00	0.50	5.00	4.00	1.50	0.050	2.00	0.60	7.00	1.00	23.00
SINGLE SAMPLE MAXIMUM	N/A	0.003	0.040	0.765	0.203	0.0007	0.072	0.013	1.234	N/A	N/A
VIOLATION(S)	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO
NUMBER OF VIOLATIONS	0	0	0	0	0	0	0	0	0	0	0
POTENTIAL NUMBER OF TRC VIOLATIONS	0	0	0	0	0	0	0	0	0	0	0
DETECTION LIMITS	0.024	0.002	0.002	0.007	0.022	0.0002	0.006	0.006	0.002	0.010	0.05
FEDERAL DAILY MAX. LIMITS	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
FEDERAL MONTHLY AVG. LIMITS	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

* EPA/Standard Methods: As,Cd,Cr,Cu,Pb,Ni,Ag,Zn - EPA200.7, Hg - EPA245.1, CN(T) - SM4500 CN-, Phenol - SM5530D
 ND = Not detected above the MDL N/A = Not Applicable TRC = TECHNICAL REVIEW CRITERIA (1.2 X LOCAL LIMIT)